

Rev. 05/25/11

Carbon Dioxide (CO<sub>2</sub>) in air is normally measured in Parts Per Million (ppm). At 1,000 ppm CO<sub>2</sub>, a volume of air containing one million air molecules would contain a mixture of 999,000 air molecules and 1,000 CO<sub>2</sub> molecules.

The volume of air necessary to contain one million air molecules is affected by air pressure and air temperature. As the pressure decreases, the volume needed to contain one million air molecules increases. The opposite is true of temperature. As the temperature decreases, the volume of air needed to contain one million molecules decreases. Although the volume of air is affected by temperature and pressure, the concentration of CO<sub>2</sub> is not affected. If you started with 1,000 ppm of CO<sub>2</sub>, then you finish with 1,000 ppm of CO<sub>2</sub> despite the changes in the air volume.

The most common CO<sub>2</sub> sensors are known by the engineering term Non-Dispersive Infrared, or NDIR. An NDIR CO<sub>2</sub> sensor shines infrared light through a gas sample in a sample chamber. Sensitive photo-detectors measure the intensity of the infrared light after it passes through the gas sample. CO<sub>2</sub> molecules are opaque to 4.26 micron infrared light while the rest of the air molecules are not. So the intensity of the infrared light is diminished proportionally to the number of CO<sub>2</sub> molecules that are present. Measuring the resultant light intensity measures the number of CO<sub>2</sub> molecules present.

The size of the NDIR sampling chamber is fixed and is open to the atmosphere so that air can move in and out. As explained above, the number of air molecules in a given volume is affected by temperature and pressure but not the concentration of CO<sub>2</sub>. At low pressures or high temperatures, there will be fewer air molecules in the sample chamber, so there will also be fewer CO<sub>2</sub> molecules, even though the ppm of CO<sub>2</sub> hasn't changed. Fewer CO<sub>2</sub> molecules "fools" the sensor into thinking that the CO<sub>2</sub> concentration is lower than it really is. At high pressures or low temperatures, there are more air molecules in the sample chamber and more CO<sub>2</sub> molecules, even though the CO<sub>2</sub> concentration hasn't changed. More CO<sub>2</sub> molecules "fools" the sensor into thinking that the CO<sub>2</sub> concentration is higher than it really is. Therefore a CO<sub>2</sub> sensor calibration will only be accurate at one temperature and one pressure.

## Calculating Temperature and Pressure Effects on CO<sub>2</sub> Measurement

The following formula derived from the Ideal Gas Law relates changes in air volume to temperature, pressure and the number of molecules present:

$$\text{ppm CO}_2 \text{ corrected} = \text{ppm CO}_2 \text{ measured} * ((T_{\text{measured}} * p_{\text{ref}}) / (p_{\text{measured}} * T_{\text{ref}}))$$

- **p<sub>measured</sub>** = Current pressure, in the same units as reference pressure (not corrected to sea level)

- **T<sub>ref</sub>** = reference temperature, usually 25°C, 77°F, converted to absolute (298.15 for °C, 536.67 for °F)

- **T<sub>measured</sub>** = Current absolute temperature, °C + 273.15, °F + 459.67

- **p<sub>ref</sub>** = reference pressure, usually sea level, 29.92 in Hg, 760 mm Hg, 1013.207 hPa or 14.6959 psi

**Table 1** uses the Ideal Gas Law and the formula above to show how the uncompensated CO<sub>2</sub> measurement would change with temperatures from 32 °F to 110 °F. Initial conditions are 1,000 ppm CO<sub>2</sub>, 77°F and sea level pressure. As seen in Table 1, the CO<sub>2</sub> concentration varies by 150 ppm.

Air pressure or barometric pressure is directly affected by altitude, and **Table 2** uses the Ideal Gas Law and formula to show how the uncompensated CO<sub>2</sub> measurement would change with altitudes of -1,000 to 10,000 feet. Initial conditions are 77°F and 1,000 ppm CO<sub>2</sub> at sea level. As seen in Table 2, the CO<sub>2</sub> concentration varies by 349 ppm.

Temp. in °F	CO <sub>2</sub> Measured in PPM	Temp. in °F	CO <sub>2</sub> Measured in PPM	Temp. in °F	CO <sub>2</sub> Measured in PPM
32	1092	60	1033	85	985
35	1085	65	1023	90	976
40	1074	70	1013	95	968
45	1063	75	1004	100	959
50	1053	77	<b>1000</b>	105	950
55	1043	80	994	110	942

Altitude in Feet	Barometric Pressure in inches Hg	CO <sub>2</sub> Measured in PPM
-1000	31.02	1037
0	29.92	<b>1000</b>
1000	28.85	964
2000	27.82	930
3000	26.82	896
4000	25.84	864
5000	24.9	832
6000	23.98	801
7000	23.09	772
8000	22.23	743
9000	21.39	715
10000	20.58	688



Rev. 05/25/11

## Weather Effects on Barometric Pressure and CO<sub>2</sub> Measurement

Heat entering our atmosphere creates weather patterns, and these patterns affect the barometric pressure by forming high pressure systems and low pressure systems. These systems influence air volumes exactly like changes in altitude, thus creating an “effective altitude” for the location. Fast moving storms can dramatically change the atmospheric pressure and effective altitude in only a few minutes.

About 15 miles from BAPI’s headquarters is an internet enabled weather station on the Mississippi River bluffs above the small town of DeSoto. Looking at historical data from that weather station from 2003 to 2011, the highest pressure, the lowest pressure and the biggest one-day pressure swing are shown in Table 3.

Due to barometric pressure changes from weather patterns, DeSoto’s “effective altitude” changed by 2,096 feet between January 15, 2005, and October 26, 2010. The “effective altitude” changed by 983 feet in one day on January 18, 2005.

If the actual CO<sub>2</sub> level was 1,000 ppm at sea level, then Table 3 shows what the measured CO<sub>2</sub> concentration would

be in DeSoto on those days. From January 15, 2005 until October 26, 2010, weather patterns alone changed the CO<sub>2</sub> measurement by 75 ppm, which is the entire accuracy specification for a typical NDIR CO<sub>2</sub> sensor. On the single day of January 18, 2005, weather patterns changed the CO<sub>2</sub> measurement by 35 ppm, which is almost 50% of the specified accuracy specification of a typical NDIR CO<sub>2</sub> sensor.

**Table 3: CO<sub>2</sub> Measurement Change with Weather Patterns**

Date	Barometric Pressure in inches Hg	Measured CO <sub>2</sub> in PPM
1/18/2005	30.71	1026
1/18/2005	29.64	991

## The Combined Effect of Temperature and Pressure on CO<sub>2</sub> Measurement

Temperature and pressure affect CO<sub>2</sub> measurement individually as well as in combination. **Table 4** shows the measured CO<sub>2</sub> concentration for the range of barometric pressures recorded in DeSoto from 2005 to 2010 along with temperatures from 50 to 90°F.

If the actual CO<sub>2</sub> concentration were 1,000 ppm at 77°F and sea level, the measured CO<sub>2</sub> concentration would vary by 161 ppm across the various temperature and pressure ranges. That variance is more than the specified accuracy of the NDIR CO<sub>2</sub> sensor.

**Table 4: CO<sub>2</sub> Measurement Change with Temperature and Barometric Pressure Combined**

		Barometric Pressure in Inches Hg						
		28.5	29	29.5	29.92	30	30.5	31
Temperature in °F	50	1003	1021	1038	1053	1056	1073	1091
	55	993	1011	1028	1043	1046	1063	1080
	60	984	1001	1018	1033	1035	1053	1070
	65	974	991	1009	1023	1026	1043	1060
	70	965	982	999	1013	1016	1033	1050
	75	956	973	990	1004	1006	1023	1040
	77	953	969	986	<b>1000</b>	1003	1019	1036
	80	947	964	980	994	997	1014	1030
	85	939	955	971	985	988	1004	1021
	90	930	946	963	976	979	995	1012

## Dynamic CO<sub>2</sub> Measurement Compensation

Due to the constantly changing nature of barometric pressure and temperature and their effect on CO<sub>2</sub> measurement, the only way to get an accurate CO<sub>2</sub> measurement with an NDIR sensor is through temperature and barometric pressure compensation. That’s why all BAPI CO<sub>2</sub> sensors have a built in barometric pressure sensor and temperature sensor.

Every eight seconds the BAPI sensor takes a CO<sub>2</sub> reading then compensates that value based on the current temperature and barometric pressure. That’s one reason why BAPI’s CO<sub>2</sub> sensor provides the most accurate CO<sub>2</sub> measurement in the industry. There is also no need for an HVAC technician to spend valuable time entering altitude compensation values into the sensor when it is received from the factory. The technician just screws the sensor to the wall and walks away. The sensor takes care of itself!