



17350_Agency01.pdf

Building Automation Products, Inc.

750 North Royal Avenue, Gays Mills, WI 54631 USA

Tel: +1-608-735-4800 • Fax: +1-608-735-4804

E-mail:sales@bapihvac.com • www.bapihvac.com

CE Declaration of Conformity

The manufacturer hereby declares that the product:

Product Name: Zone Pressure Sensor

Product Number: ZPS-20-SR##-EU-#T-#M#, ZPS-20-SR##-BB-#T-#M#,
ZPS-05-SR##-EU-#T-#M#, ZPS-05-SR##-BB-#T-#M#,
ZPS-10-SR##-EU-#T-#M#, ZPS-10-SR##-BB-#T-#M#
(# indicates any combination of numbers or letters)

Product Options: Multiple Pressure Ranges

Date of Issue: 03/10/2006

Conforms to the following standards or other normative documents:

Electronic Emission: EN50081-1:1998
(by Council Directive 89/336/EEC) Radiated EN55022: 1998 Class B limit
Conducted EN55022: 1998 Class B limit
EN61000-3: Class A limit

Electromagnetic Immunity EN61000-6-2
(by Council Directive 89/336/EEC) EN61000-4-2 ±4 kV contact discharge
±8 kV air discharge

EN61000-4-3 10 V/M

EN61000-4-4 ±1 kV Power
±0.5kV Signal

EN61000-4-5 ±0.5kV

EN61000-4-6 3 V

EN61000-4-8 30 A/m

EN61000-4-11 Class A

This document certifies that the aforementioned products comply with the requirements of Council Directives 89/336/EEC and carry the "CE" mark accordingly.

Signature of Manufacturer

Mark Eric Nurczyk
Product Engineer
Building Automation Products, Inc
750 North Royal Ave.
Gays Mills, WI 54631 USA