



13364\_Agency01.pdf

# Building Automation Products, Inc.

750 North Royal Avenue, Gays Mills, WI 54631 USA

Tel: +1-608-735-4800 • Fax: +1-608-735-4804

E-mail:sales@bapihvac.com • www.bapihvac.com

## CE Declaration of Conformity

The manufacturer hereby declares that the product:

**Product Name:** Humidity or Humidity/Temperature Combination Units

**Product Number:** BA/H#-R#, BA/1.8K-H#-R#, BA/2.2K-H#-R#, BA/3K-H#-R#, BA/3.3K-H#-R#, BA/10K-2-H#-R#, BA/10K-3-H#-R# and BA/10K-3(11K)-H#-R# (# indicates any combination of numbers or letters)

**Product Options:** 2% or 3% humidity range with or without display

**Date of Issue:** 11/04/2003

Conforms to the following standards or other normative documents:

**Electronic Emission:** EN50081-1:1998  
 (by Council Directive 89/336/EEC) Radiated EN55022: 1998 Class A limit  
 Conducted EN55022: 1998 Class A limit

**Electromagnetic Immunity** EN61000-6-2  
 (by Council Directive 89/336/EEC) EN61000-4-2 ±4 kV contact discharge  
 ±8 kV air discharge

EN61000-4-3 3 V/M

EN61000-4-4 ±1 kV Power  
 ±0.5kV Signal

EN61000-4-5 ±1kV

EN61000-4-6 3 V

EN61000-4-8 1 A/m

This document certifies that the aforementioned products comply with the requirements of Council Directives 89/336/EEC and carry the "CE" mark accordingly.

Signature of Manufacturer

Mark Eric Nurczyk  
 Product Engineer  
 Building Automation Products, Inc  
 750 North Royal Ave.  
 Gays Mills, WI 54631  
 USA