



13363\_Agency01.pdf

# Building Automation Products, Inc.

750 North Royal Avenue, Gays Mills, WI 54631 USA

Tel: +1-608-735-4800 • Fax: +1-608-735-4804

E-mail:sales@bapihvac.com • www.bapihvac.com

## CE Declaration of Conformity

The manufacturer hereby declares that the product:

- Product Name:** 1.8K, 2.2K, 3K, 3.3K, 10K-2, 10K-3 and 10K-3(11K)  
Thermistor Product Family
- Product Number:** BA/1.8K-#, BA/2.2K-#, BA/3K-#, BA/3.3K-#  
BA/10K-2-#, BA/10K-3-#, BA/10K-3(11K)-#  
(# indicates any combination of numbers or letters)
- Product Options:** All products and options using the 1.8K, 2.2K, 3K, 3.3K,  
10K-2, 10K-3 and 10K-3(11K) Thermistors that do not have  
an LCD display or transmitter
- Date of Issue:** 07/15/2002

Conforms to the following standards or other normative documents:

- Electromagnetic Immunity:** EN61000-6-2  
(by Council Directive 89/336/EEC)
- EN61000-4-2      ±4 kV contact discharge  
                             ±8 kV air discharge
- EN61000-4-3      10 V/m
- EN61000-4-4      ±1 kV
- EN61000-4-6      10 V
- EN61000-4-8      30 A/m

This document certifies that the aforementioned products comply with the requirements of Council Directives 89/336/EEC and carry the "CE" mark accordingly.

Signature of Manufacturer

Mark Eric Nurczyk  
Product Engineer  
Building Automation Products, Inc  
750 North Royal Ave.  
Gays Mills, WI 54631  
USA